

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION  
OFFICE OF THE STATE FIRE MARSHAL  
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

# LISTING SERVICE

**LISTING No.** 7136-1501:126 Page 1 of 1

**CATEGORY:** Audible Devices for Hazardous Locations

**LISTEE:** Edwards, 90 Fieldstone Court, Cheshire, CT 06410  
Contact: David Mazur (203) 699-3300 ext. 3155

**DESIGN:** Adaptatone-Millennium Model 5530MD-24AW and Model 5532MD followed by -10, -25, or -70, followed by AW audible signal device. Unit accepts externally generated 10, 25 or 70 Vrms signals for amplification as a sound output. Unit may produce up to 27 different tones. Refer to listee's data sheet for additional detailed product description and operational considerations.

**RATING:** 20-31 VDC

**INSTALLATION:** In accordance with listee's printed installation instructions, applicable codes & ordinances and in a manner acceptable to the authority having jurisdiction. Suitable for outdoor use (type 3R enclosure).

**MARKING:** Listee's name, model number, electrical rating and UL label.

**APPROVAL:** Listed as audible signal electronic horn for use with separately listed compatible fire alarm control units. Suitable for hazardous locations Class I, Division 2, Groups A, B, C and D, T4; Class II, Division 2, Groups F and G, T5; and Class III, T5.

These units can produce the distinctive three-pulse Temporal Pattern Fire Alarm Evacuation Signal (for total evacuation) in accordance with NFPA 72, 1996 Edition. Refer to manufacturer's Installation Manual for details.

05-17-2002



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued:

**JULY 23, 2002**

*Listing Expires **June 30, 2003***

Authorized By:

**DIANE K. AREND**, Senior Deputy  
Program Manager